

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7135-1477:112 Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Mircom Technologies, Ltd.* , 8111 Jane Street, Vaughan, Ontario L4K 4L7 Canada
Contact: *Mara Cherubin (888) 660-4655 Fax (888) 660-4113

DESIGN: Model FHS-240 audible/visual device. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC
All strobes rated at 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and audibility ratings and UL label.

APPROVAL: Listed as horns or horn/strobes for use with separately listed compatible fire alarm control units. Models with strobe are suitable for the hearing impaired applications and intended for indoor use only.

Units can generate a distinctive three pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

XLF: 7135-0587:118

*Rev. 06-18-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager